CIVIL QUALITY
CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

05.05.2022

TEST REPORT ON CEMENT

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Sample ID: : Cement (Birla Super 53 grade OPC)

Sample Supplied by: : AGENCY

Date of Manufacture: :April-2022

Date of Testing 03.05.2022 to 05.05.2022

Sl.No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 269:2015
1	a) Initial Setting Time	IS-4031 (Part - 5):1988(RA 2014)	125 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part - 5):1988(RA 2014)	350 Minutes	Not More than 600 Minutes
2	Soundness	IS-4031 (Part 3) :1988 (RA 2014) by the Le-Chatelier method	1 mm	Not more than 10 mm
3	Standard Consistency	IS-4031 (Part -4)	30.00%	-

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Note:

1. The Material is satisfied as per the requirement.

ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY
CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23 Date 05.05.2022

TEST REPORT ON FINE AGGREGATES (SAND)

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Date of Testing 05.05.2022

IS Code : IS 383:2016

: IS 2386 (Part 1):1963(RA 2011)

Material : Sand Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Requirements as per IS 383:2016 Spec.Limits For Zone-II
10	0	0	0	100	100
4.75	62	6.20	6.20	93.8	90-100
2.36	98	9.80	16.00	84.0	75-100
1.18	164	16.40	32.40	67.6	55-90
600 Micron	212	21.20	53.60	46.4	35-59
300 Micron	258	25.80	79.40	20.6	8-30
150 Micron	164	16.40	95.80	4.2	0-10

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY
CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Date 05.05.2022

Job No.: CQCE/BBMP/DM/17/2022-23

TEST REPORT ON COARSE AGGREGATES

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Date of Testing 05.05.2022

IS Code : IS 383:2016

: IS 2386 (Part 1):1963(RA 2011)

Material : 40mm Aggregates

Total Wt. of Aggregates in gms **15000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Requirements as per IS 383:2016
80	0	0	0	100	100
40	202	1.35	1.35	98.65	95-100
20	8416	56.11	57.45	42.55	30-70
10	3057	20.38	77.83	22.17	10-35
4.75	2698	17.99	95.82	4.18	0-5

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY
CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Date 05.05.2022

Job No.: CQCE/BBMP/DM/17/2022-23

TEST REPORT ON COARSE AGGREGATES

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Date of Testing 05.05.2022

IS Code : IS 383:2016

: IS 2386 (Part 1):1963(RA 2011)

Material : 20mm Aggregates

Total Wt. of Aggregates in gms= 5000

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Requirements as per IS 383:2016
40	0	0	0	100	100
20	220	4.4	4.4	95.6	95-100
10	2649	53.0	57.4	42.6	25-55
4.75	1965	39.3	96.7	3.3	0-10

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23 Date 05.05.2022

TEST REPORT ON FINE AGGREGATES (SAND)
IS 1542-1992

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Date of Testing 05.05.2022

Material : Sand(Plastering) Total wt. of aggregates in gms = **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits as per IS 1542-1992
10	0	0	0	100	100
4.75	28	2.80	2.80	97.2	95-100
2.36	19	1.90	4.70	95.3	95-100
1.18	34	3.40	8.10	91.9	90-100
600 Micron	62	6.20	14.30	85.7	80-100
300 Micron	253	25.30	39.60	60.4	20-65
150 Micron	510	51.00	90.60	9.4	0-15

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date 05.05.2022

TEST REPORT ON FINE AGGREGATES (SAND)
IS 2116-1980

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of Work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Date of Testing 05.05.2022

Material : Sand(Masonry) Total wt. of aggregates in gms = **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Spec.Limits as per IS 2116-1980
4.75	0	0.00	0.00	100.0	100
2.36	20	2.00	2.00	98.0	90-100
1.18	26	2.60	4.60	95.4	70-100
600 Micron	62	6.20	10.80	89.2	40-100
300 Micron	249	24.90	35.70	64.3	5-70
150 Micron	505	50.50	86.20	13.8	0-15

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 17.05.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of the work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	17.05.2022	8.061	332.6	14.78
2	10.05.2022	17.05.2022	8.184	345.8	15.37
3	10.05.2022	17.05.2022	8.197	352.1	15.65

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 07.06.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.
Agency	: **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.
Name of the work	: Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	07.06.2022	8.032	511.8	22.75
2	10.05.2022	07.06.2022	8.164	527.9	23.46
3	10.05.2022	07.06.2022	8.015	535.6	23.80

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 17.05.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	**: Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.
Agency	**: Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.
Name of the work	: Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	17.05.2022	8.002	340.0	15.11
2	10.05.2022	17.05.2022	8.132	350.0	15.56
3	10.05.2022	17.05.2022	8.174	360.0	16.00

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 07.06.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	**: Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.
Agency	**: Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.
Name of the work	: Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	07.06.2022	8.198	502.3	22.32
2	10.05.2022	07.06.2022	8.004	526.9	23.42
3	10.05.2022	07.06.2022	8.021	534.5	23.76

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬ್ರಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 17.05.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of the work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	17.05.2022	8.163	339.5	15.09
2	10.05.2022	17.05.2022	8.015	346.1	15.38
3	10.05.2022	17.05.2022	8.117	357.8	15.90

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/DM/17/2022-23

Date: 07.06.2022

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Assistant Executive Engineer,** Yashwanthpura Sub Division, BBMP, Bangalore.

Agency : **Sri. Damodar Manjunath (K Damodar and Co),** Contractor, Bangalore.

Name of the work : Construction of Individual Houses in Ward No 17 RR Nagar Constituency, BBMP, Bangalore.

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	10.05.2022	07.06.2022	8.178	510.0	22.67
2	10.05.2022	07.06.2022	8.069	520.0	23.11
3	10.05.2022	07.06.2022	8.001	530.0	23.56

Note:

1. The Material is satisfied as per the requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಯಶವಂತಪುರ ಉಪ ವಿಭಾಗ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner